



Sheep River

Treated I

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)
2024-01-01	652	863	1515	12.86
2024-01-02	624	876	1500	11.11
2024-01-03	632	882	1513	12.16
2024-01-04	651	886	1536	11.49
2024-01-05	649	874	1523	19.82
2024-01-06	677	884	1561	12.30
2024-01-07	690	899	1589	10.35
2024-01-08	646	889	1535	11.95
2024-01-09	677	916	1592	13.50
2024-01-10	707	898	1605	13.22
2024-01-11	722	897	1619	12.91
2024-01-12	687	908	1594	11.02
2024-01-13	685	939	1624	11.02
2024-01-14	736	933	1669	10.62
2024-01-15	701	970	1671	13.79
2024-01-16	699	965	1664	13.55
2024-01-17	663	935	1598	12.06
2024-01-18	702	925	1627	12.19
2024-01-19	701	934	1635	14.79
2024-01-20	688	936	1624	12.12
2024-01-21	697	954	1651	12.50
2024-01-22	679	991	1670	14.63
2024-01-23	653	962	1614	12.39
2024-01-24	662	945	1607	14.14
2024-01-25	645	939	1583	11.39
2024-01-26	658	946	1604	12.51
2024-01-27	713	941	1654	10.00
2024-01-28	692	951	1643	9.05
2024-01-29	639	956	1595	9.71
2024-01-30	669	953	1622	8.40
2024-01-31	688	946	1634	8.53

Min	624	863	1500	8.40
Avg	677	926	1602	12.13
Max	736	991	1671	19.82
Total m3	20982	28691	49674	376.08

Raw water reservoir in m3 at the end of the month	168282	Raw water reservoir in percentage
---	--------	-----------------------------------

er Regional Utility Corporation

Daily Demand vs Raw Water Diversion

Total Treated Water (m3/day)	Diamond Valley West TW7, TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley East VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)
1528	0	697	1036	1733
1511	0	725	1035	1760
1526	0	734	1036	1770
1548	0	698	1035	1733
1543	0	724	1036	1760
1573	0	734	1035	1769
1599	0	699	1036	1735
1547	0	724	1036	1760
1606	0	733	1049	1782
1618	0	701	1039	1740
1632	0	725	1036	1761
1606	0	737	1035	1772
1635	0	697	1036	1733
1680	0	728	1063	1791
1685	0	736	1123	1859
1678	0	697	1122	1819
1610	0	732	1121	1853
1639	0	744	1122	1866
1650	0	697	1122	1819
1636	0	735	1122	1857
1663	0	748	1122	1870
1685	0	697	1122	1819
1627	0	733	1121	1854
1621	0	743	1123	1866
1595	0	698	1122	1820
1617	0	730	1122	1852
1664	0	741	1122	1863
1652	0	697	1122	1819
1605	0	730	1121	1851
1630	0	741	1122	1863
1643	0	697	1122	1819

1511	0	697	1035	1733
1614	0	721	1084	1805
1685	0	748	1123	1870
50050	0	22352	33616	55968

90.2	Max 1310 m3/day	Max 1443 m3/day	I/O Max 2488 m3/day Max 6480 m3/day
------	-----------------	-----------------	---

DV & MC RAW Water Volume Used (m3/day)	Raw Water Daily Gain/Loss (m3)
1763	-30
1810	-50
1841	-71
2008	-275
1740	20
1794	-25
1838	-103
2118	-358
1924	-142
1815	-75
1814	-53
1896	-124
2186	-453
2010	-219
2034	-175
1975	-156
1803	50
2226	-360
1972	-153
1966	-109
1938	-68
2080	-261
2087	-233
2189	-323
1891	-71
1834	18
1880	-17
1845	-26
1980	-129
1818	45
1840	-21

1740	-453
1933	-131
2226	50
59915	-3947

