



Sheep River Regional Utility Corporation Water Usage Report

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2024-02-01	628	955	1583	7	1590	2027	437	0	731	1122	1853	90.3
2024-02-02	593	958	1550	6	1557	1839	283	0	744	1122	1866	90.5
2024-02-03	591	931	1522	7	1529	1903	374	0	697	1122	1819	90.6
2024-02-04	628	928	1556	7	1563	2099	536	0	732	1054	1786	90.9
2024-02-05	607	941	1547	10	1558	1802	244	0	742	1004	1746	90.8
2024-02-06	611	933	1544	16	1560	1782	223	0	347	1012	1359	90.9
2024-02-07	618	940	1558	12	1570	2032	462	0	732	1012	1744	90.5
2024-02-08	587	930	1517	15	1532	1913	381	0	743	1011	1754	90.6
2024-02-09	677	937	1614	14	1628	1951	323	0	698	1005	1703	90.7
2024-02-10	643	964	1607	11	1618	2062	444	0	731	980	1711	90.4
2024-02-11	644	971	1615	8	1623	1785	162	0	739	984	1723	90.4
2024-02-12	598	975	1573	10	1583	1780	197	0	698	995	1693	90.4
2024-02-13	612	950	1562	12	1574	2055	481	0	730	991	1721	90.4
2024-02-14	675	947	1622	10	1632	2030	399	0	742	994	1736	90.3
2024-02-15	721	952	1673	10	1683	1895	212	0	697	1022	1719	90.2
2024-02-16	705	983	1687	12	1700	1675	-25	0	724	984	1708	90.0
2024-02-17	697	981	1678	10	1688	2127	439	0	723	989	1712	90.0
2024-02-18	711	979	1689	9	1699	2041	343	0	699	990	1689	89.8
2024-02-19	723	976	1698	9	1708	2039	332	0	731	986	1717	89.5
2024-02-20	703	976	1679	11	1690	2188	498	0	742	986	1728	89.6
2024-02-21	714	969	1682	9	1692	1912	221	0	697	992	1689	89.2
2024-02-22	725	962	1687	9	1696	2040	344	0	775	994	1769	89.1
2024-02-23	718	951	1668	9	1678	2107	430	0	875	992	1867	89.3
2024-02-24	705	956	1662	10	1671	2075	404	0	964	988	1952	89.2
2024-02-25	730	954	1684	8	1692	1910	218	0	1052	990	2042	89.3
2024-02-26	699	962	1661	11	1672	1668	-4	0	1052	983	2035	89.5
2024-02-27	699	952	1651	9	1660	1799	139	0	1052	986	2038	89.7
2024-02-28	832	958	1789	9	1799	2307	508	0	1051	979	2030	89.7
2024-02-29	883	949	1831	8	1840	2373	533	0	1054	1000	2054	89.9

Min	587	928	1517	6.11	1529	1668		0	347	979	1359	89.1
Avg	679	956	1634	9.93	1644	1973	329	0	783	1009	1792	90.1
Max	883	983	1831	15.60	1840	2373		0	1054	1122	2054	90.9
Total m3	19677	27715	47392	288.05	47680	57216	9536	0	22694	29269	51963	

↑
Cells will highlight red if volume is if above 3000 m3/ per day for DV.

16.67%
Loss

Total Volume Overflow	186,560	100.00%
Max Safe Level	173,501	93.0%
Average Month Volume	168,013	