



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2024-04-01	714	1055	1769	6.07	1775	2109	334	0	785	907	1692	98.8
2024-04-02	707	1039	1746	7.33	1753	2215	462	0	911	907	1818	98.6
2024-04-03	708	1012	1720	6.17	1726	1823	97	0	1023	904	1927	98.4
2024-04-04	690	982	1672	5.71	1678	1912	234	0	1140	907	2047	98.7
2024-04-05	653	987	1640	6.14	1646	1886	240	0	1012	907	1919	99.4
2024-04-06	685	985	1670	4.65	1675	1826	151	0	963	704	1667	99.2
2024-04-07	722	1006	1728	5.95	1734	2427	693	0	962	750	1712	99.1
2024-04-08	694	1043	1737	9.19	1746	1879	133	0	955	811	1766	98.7
2024-04-09	689	1054	1743	8.29	1751	1968	217	0	1071	907	1978	98.5
2024-04-10	685	1076	1761	7.37	1768	2018	250	0	1078	906	1984	98.8
2024-04-11	689	1146	1835	8.21	1843	1997	154	0	1050	907	1957	98.7
2024-04-12	677	1167	1844	7.67	1852	2407	555	0	1051	906	1957	98.7
2024-04-13	711	1147	1858	6.84	1865	2094	229	0	1159	906	2065	98.5
2024-04-14	748	1159	1907	8.34	1915	2154	239	127	1345	253	1725	98.6
2024-04-15	729	1152	1881	11.19	1892	2126	234	266	1139	0	1405	97.9
2024-04-16	708	1129	1837	8.89	1846	2316	470	241	1034	527	1802	97.2
2024-04-17	725	1136	1861	10.06	1871	2154	283	230	1162	905	2297	97.7
2024-04-18	700	1140	1840	8.32	1848	2091	243	237	1206	907	2350	97.9
2024-04-19	708	1148	1856	7.39	1863	2108	245	234	1206	906	2346	98.0
2024-04-20	683	1147	1830	9.33	1839	2205	366	244	1002	906	2152	98.3
2024-04-21	761	1152	1913	6.92	1920	2208	288	242	1034	906	2182	98.1
2024-04-22	712	1159	1871	7.76	1879	2093	214	229	1193	255	1677	97.8
2024-04-23	760	976	1736	4.80	1741	1953	212	244	1088	0	1332	96.9
2024-04-24	740	890	1630	7.89	1638	1881	243	239	1120	0	1359	96.3
2024-04-25	745	888	1633	5.82	1639	2191	553	237	1357	0	1594	96.2
2024-04-26	681	874	1555	6.89	1562	1719	157	238	1120	0	1358	95.4
2024-04-27	678	870	1548	5.28	1553	1822	269	238	1120	0	1358	95.2
2024-04-28	763	868	1632	8.54	1640	1771	131	236	1120	0	1356	94.9
2024-04-29	669	874	1543	9.40	1552	2226	674	235	1120	527	1882	94.5
2024-04-30	678	852	1530	6.61	1537	1658	121	236	1119	903	2258	95.9
Min	653	852	1530	4.65	1537	1658		0	785	0	1332	94.5
Avg	707	1037	1744	7.43	1752	2041	290	132	1088	611	1831	97.8
Max	763	1167	1913	11.19	1920	2427		266	1357	907	2350	99.4
Total m3	21211	31113	52324	222.99	52547	61237	8690	3953	32645	18324	54922	

↑
Cells will highlight red if volume is if above
3000 m3/ per day for DV.

14.19%
Loss

Full Level
End of Month
Average Month Volume

186,403
178,760
182,222

100.00%
95.9%