



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2024-06-01	751	980	1731	8.55	1740	2146	406	151	1516	0	1667	97.1
2024-06-02	822	1016	1838	10.96	1849	2384	535	150	1518	0	1668	96.7
2024-06-03	796	1037	1833	8.92	1842	2192	350	148	1517	0	1665	96.3
2024-06-04	719	933	1652	9.99	1662	1813	151	146	1516	0	1662	96.0
2024-06-05	804	945	1749	11.70	1761	2228	468	147	1516	0	1663	95.8
2024-06-06	855	956	1810	13.38	1824	2715	892	169	1429	495	2093	95.5
2024-06-07	789	940	1729	9.04	1738	1847	109	178	1380	944	2502	95.8
2024-06-08	775	922	1697	9.69	1707	1923	216	179	1386	851	2416	96.2
2024-06-09	794	938	1731	12.09	1744	2242	499	177	1384	865	2426	96.4
2024-06-10	784	951	1734	19.38	1754	2191	437	175	1384	464	2023	96.8
2024-06-11	777	910	1687	19.01	1706	1795	89	175	1385	0	1560	95.8
2024-06-12	850	927	1778	21.55	1799	2009	210	189	1384	607	2180	95.5
2024-06-13	857	970	1828	23.54	1851	2514	663	172	1383	833	2388	96.3
2024-06-14	765	964	1730	18.73	1748	1865	117	166	1414	908	2488	96.3
2024-06-15	718	931	1649	20.67	1670	2084	414	165	1426	988	2579	96.8
2024-06-16	710	882	1592	16.67	1609	1768	160	153	1480	436	2069	97.8
2024-06-17	771	863	1634	17.68	1652	2114	463	157	1512	0	1669	97.3
2024-06-18	707	843	1550	20.68	1571	1877	306	153	1513	0	1666	97.5
2024-06-19	768	860	1628	19.65	1648	1829	181	152	1512	0	1664	97.5
2024-06-20	800	910	1711	19.80	1730	1817	87	160	1462	0	1622	97.2
2024-06-21	722	887	1609	20.50	1629	2323	694	153	1424	0	1577	96.9
2024-06-22	745	878	1622	17.13	1640	1813	174	153	1424	0	1577	96.4
2024-06-23	835	917	1751	33.31	1785	2143	359	156	1420	0	1576	96.3
2024-06-24	812	954	1765	21.49	1787	2185	398	146	1451	733	2330	95.9
2024-06-25	776	929	1704	25.49	1730	2283	554	148	1468	941	2557	96.8
2024-06-26	784	948	1732	20.15	1752	2052	300	149	1467	928	2544	97.3
2024-06-27	752	899	1651	21.85	1673	1960	287	147	1467	892	2506	97.7
2024-06-28	665	860	1525	18.20	1543	1754	211	150	1467	405	2022	99.5
2024-06-29	679	839	1518	21.91	1540	2080	540	152	1490	0	1642	98.8
2024-06-30	687	819	1506	19.95	1526	1652	126	148	1573	0	1721	98.5
Min	665	819	1506	8.55	1526	1652		146	1380	0	1560	95.5
Avg	769	920	1689	17.72	1707	2053	346	159	1456	376	1991	96.8
Max	857	1037	1838	33.31	1851	2715	892	189	1573	988	2579	99.5
Total m3	23070	27605	50675	531.65	51207	61598	10392	4764	43668	11289	59721	

↑
Cells will highlight red if volume is above 3000 m3/ per day for DV.

16.87%
Loss

Full Level
End of Month
Average Month Volume

186,403
183,607
180,482

100.00%
98.5%