



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2024-08-01	1046	1166	2212	16	2228	2938	710	124	1228	1076	2428	96.8
2024-08-02	918	1165	2083	11	2094	2322	228	52	1250	1253	2555	96.7
2024-08-03	841	1096	1937	10	1947	2485	538	24	1284	1314	2622	96.8
2024-08-04	756	996	1753	10	1762	2134	372	78	1293	1189	2560	97.1
2024-08-05	835	940	1775	7	1782	2183	401	127	1273	1389	2789	97.4
2024-08-06	718	922	1639	8	1648	1950	303	119	1294	526	1939	98.1
2024-08-07	762	902	1664	6	1670	1873	203	122	1293	0	1415	98.7
2024-08-08	804	934	1737	19	1757	2117	361	123	1293	0	1416	97.7
2024-08-09	761	944	1705	34	1739	2133	394	102	1293	315	1710	98.6
2024-08-10	764	965	1728	9	1738	1927	190	143	1293	912	2348	98.4
2024-08-11	830	1035	1865	25	1889	2317	428	146	1293	912	2351	98.7
2024-08-12	848	1055	1903	8	1911	2237	326	151	1272	908	2331	98.9
2024-08-13	757	996	1753	32	1785	1888	103	149	1246	907	2302	98.8
2024-08-14	776	899	1675	11	1686	2207	522	148	1250	911	2309	99.1
2024-08-15	872	885	1757	82	1839	2174	335	148	1250	901	2299	98.0
2024-08-16	734	849	1584	9	1592	1693	101	147	1250	900	2297	97.5
2024-08-17	741	849	1590	10	1600	1908	308	144	1250	901	2295	97.0
2024-08-18	825	892	1716	9	1726	2039	314	143	1250	899	2292	97.9
2024-08-19	834	902	1736	46	1782	2220	438	149	1169	900	2218	96.9
2024-08-20	786	890	1676	12	1688	1881	193	133	1190	903	2226	97.1
2024-08-21	823	933	1756	8	1764	1856	92	142	1207	907	2256	97.2
2024-08-22	814	948	1761	12	1774	2450	677	141	1206	906	2253	97.5
2024-08-23	749	940	1689	8	1697	1934	237	139	1207	880	2226	97.5
2024-08-24	726	894	1620	44	1664	2519	855	137	1207	874	2218	97.9
2024-08-25	747	895	1642	11	1653	2573	920	144	1174	875	2193	98.1
2024-08-26	752	887	1639	10	1649	1905	257	137	1153	869	2159	98.1
2024-08-27	690	901	1590	11	1602	1831	229	137	1164	866	2167	98.4
2024-08-28	684	868	1552	5	1557	1881	324	137	1164	859	2160	98.3
2024-08-29	717	872	1589	5	1594	1834	240	137	1164	179	1480	99.2
2024-08-30	700	878	1577	6	1584	2152	569	137	1164	0	1301	100
2024-08-31	690	886	1576	10	1586	1797	211	138	1164	0	1302	100
Min	684	849	1552	4.92	1557	1693		24	1153	0	1301	96.7
Avg	784	941	1725	16.34	1741	2108	367	129	1232	782	2142	98.0
Max	1046	1166	2212	82.18	2228	2938		151	1294	1389	2789	99.5
Total m3	24297	29182	53479	506.47	53985	65358	11373	3998	38188	24229	66415	

↑
Cells will highlight red if volume is above 3000 m3/ per day for DV.

17.40%
Loss

Full Level
End of Month
Average Month Volume

186,403
186,403
182,639

100.00%
100.0%