



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2024-07-01	756	840	1595	17	1613	1824	212	147	1597	0	1744	98.8
2024-07-02	721	860	1580	22	1603	1778	176	150	1596	0	1746	99.0
2024-07-03	702	860	1562	18	1580	2100	520	147	1597	0	1744	99.1
2024-07-04	754	876	1630	22	1652	1770	118	143	1596	0	1739	98.9
2024-07-05	750	873	1623	18	1641	1931	290	144	1596	0	1740	98.7
2024-07-06	738	900	1638	23	1661	2037	376	141	1596	0	1737	98.7
2024-07-07	824	966	1789	27	1816	2190	374	139	1596	0	1735	98.4
2024-07-08	935	1022	1957	21	1978	2392	414	138	1596	0	1734	98.3
2024-07-09	851	1016	1867	25	1892	2145	253	135	1596	0	1731	97.8
2024-07-10	944	1047	1991	25	2016	2112	96	144	1524	409	2077	97.3
2024-07-11	1043	1060	2103	25	2128	2886	758	137	1466	972	2575	97.8
2024-07-12	851	1030	1881	22	1903	1999	96	137	1466	963	2566	97.8
2024-07-13	850	990	1840	30	1870	2157	287	134	1466	1029	2629	97.8
2024-07-14	866	1008	1874	24	1898	2227	329	134	1466	1043	2643	98.4
2024-07-15	866	986	1852	24	1876	2194	318	133	1466	1011	2610	98.8
2024-07-16	816	992	1808	32	1840	2119	279	134	1432	473	2039	99.0
2024-07-17	875	1019	1894	27	1921	2021	100	130	1424	0	1554	98.0
2024-07-18	866	1082	1948	27	1975	2608	633	130	1423	0	1553	97.4
2024-07-19	860	1073	1933	22	1955	2127	172	131	1396	0	1527	96.7
2024-07-20	863	1067	1930	29	1959	2056	97	129	1380	0	1509	96.0
2024-07-21	969	1117	2086	29	2115	2821	706	129	1380	0	1509	95.6
2024-07-22	970	1143	2113	27	2140	2226	96	124	1380	786	2290	94.7
2024-07-23	950	1118	2068	43	2111	2281	170	124	1380	1115	2619	95.7
2024-07-24	1050	1130	2180	36	2216	2721	505	124	1379	1205	2708	95.8
2024-07-25	955	1146	2101	22	2123	2454	331	137	1271	1252	2660	96.1
2024-07-26	847	1060	1907	12	1919	2115	196	130	1207	1254	2591	95.8
2024-07-27	903	1039	1942	19	1961	2397	436	129	1207	1324	2660	95.9
2024-07-28	1001	1084	2085	23	2108	2296	188	129	1207	1380	2716	96.2
2024-07-29	982	1091	2073	17	2090	2603	513	129	1206	1380	2715	96.6
2024-07-30	894	1081	1975	20	1995	2421	426	128	1206	1316	2650	96.8
2024-07-31	988	1127	2115	21	2136	2216	80	127	1206	1271	2604	96.7
Min	702	840	1562	12.32	1580	1770		124	1206	0	1509	94.7
Avg	879	1023	1901	24.18	1925	2233	308	134	1429	587	2150	97.4
Max	1050	1146	2180	43.02	2216	2886		150	1597	1380	2716	99.1
Total m3	27239	31702	58941	749.49	59690	69224	9534	4167	44304	18183	66654	

↑
Cells will highlight red if volume is above 3000 m3/ per day for DV.

13.77%
Loss

Full Level
End of Month
Average Month Volume

186,403
180,252
181,508

100.00%
96.7%