



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2024-09-01	723	885	1609	10	1618	1701	83	137	1164	0	209	99.8
2024-09-02	859	922	1781	9	1790	2205	415	136	1164	0	45	98.8
2024-09-03	757	937	1694	35	1729	2152	424	137	1164	0	256	98.9
2024-09-04	733	913	1646	9	1655	1734	79	134	1164	531	0	97.7
2024-09-05	759	947	1706	12	1718	2017	299	133	1164	910	0	97.3
2024-09-06	729	970	1699	13	1712	2071	359	134	1164	896	0	96.9
2024-09-07	727	968	1696	10	1705	2134	429	131	1164	880	0	96.1
2024-09-08	781	964	1745	10	1755	1867	112	131	1164	876	0	95.5
2024-09-09	715	995	1709	11	1721	2128	408	130	1164	106	0	95.0
2024-09-10	647	1014	1661	10	1671	2029	358	128	1164	0	0	94.3
2024-09-11	674	954	1627	48	1676	2001	326	128	1164	0	0	93.7
2024-09-12	724	911	1635	6	1641	1978	337	127	1164	0	0	93.2
2024-09-13	648	857	1505	7	1512	1858	346	127	1164	0	0	93.2
2024-09-14	647	839	1486	4	1490	1863	373	126	1164	0	0	92.8
2024-09-15	717	831	1547	5	1553	1855	303	127	1164	0	0	92.4
2024-09-16	727	856	1583	10	1593	1856	263	125	1164	0	0	92.0
2024-09-17	672	829	1501	8	1509	1863	355	105	1164	0	0	91.6
2024-09-18	675	850	1525	8	1533	1999	466	137	1164	0	401	91.3
2024-09-19	680	844	1524	58	1582	1712	130	138	1164	467	868	91.5
2024-09-20	646	838	1484	11	1495	1990	496	139	1164	906	863	92.1
2024-09-21	655	834	1489	11	1500	1763	264	148	1115	898	865	92.6
2024-09-22	699	820	1520	10	1529	1959	430	144	1078	879	863	92.9
2024-09-23	660	856	1515	9	1525	1770	245	145	1078	873	864	93.2
2024-09-24	658	852	1510	14	1523	1893	370	145	1078	902	840	93.2
2024-09-25	656	878	1534	11	1545	1793	249	145	1077	921	865	93.6
2024-09-26	634	850	1484	35	1519	2111	592	144	1078	910	864	93.8
2024-09-27	685	834	1519	11	1530	1684	154	144	1078	909	964	93.7
2024-09-28	692	846	1538	12	1550	1695	145	143	1078	912	864	93.9
2024-09-29	707	834	1540	10	1551	2125	575	141	1078	911	864	94.1
2024-09-30	700	834	1534	11	1545	1915	370	139	1084	910	868	94.3
Min	634	820	1484	4.28	1490	1684		105	1077	0	0	91.3
Avg	700	885	1585	14.24	1599	1924	325	135	1137	487	379	94.3
Max	859	1014	1781	57.67	1790	2205		148	1164	921	964	99.8
Total m3	20986	26559	47545	427.06	47972	57721	9749	4048	34102	14597	11363	

↑
Cells will highlight red if volume is above
3000 m3/ per day for DV.

16.89%
Loss

Full Level
End of Month
Average Month Volume

186,403
175,778
175,803

100.00%
94.3%