## Sheep River Regional Utility Corp.
## AESRD Approval No. 1242-03-00

| Collection Date | Operator (Initials) | Collection Time | Sample Collection Site | ID Number | Testing Results | | Chlorine Residual | Samples Collected |
|---|---|---|---|---|---|---|---|---|
| | | | | | Total Coliform | E-coli | | |
| 05-Jul-23 | CL | 7:35 AM | WTP to DV East | 2156496 | ABSENT | ABSENT | 0.98 | 8 |
| 05-Jul-23 | CL | 7:30 AM | WTP to DV West - Sheep River | 2156495 | ABSENT | ABSENT | 1.04 | |
| 13-Jul-23 | CA | 10:40 AM | BD sample point | 2156493 | ABSENT | ABSENT | 0.80 | |
| 13-Jul-23 | CA | 10:45 AM | TV sample point | 2156492 | ABSENT | ABSENT | 0.93 | |
| 20-Jul-23 | CA | 8:10 AM | TV sample point | 2156491 | ABSENT | ABSENT | 1.16 | |
| 20-Jul-23 | CA | 8:20 AM | BD sample point | 2156490 | ABSENT | ABSENT | 1.08 | |
| 26-Jul-23 | CA | 8:15 AM | TV sample point | 2156486 | ABSENT | ABSENT | 1.36 | |
| 26-Jul-23 | CA | 8:22 AM | BD sample point | 2156487 | ABSENT | ABSENT | 1.20 | |
| 02-Aug-23 | CA | 8:05 AM | BD sample point | 2156483 | ABSENT | ABSENT | 0.91 | 10 |
| 02-Aug-23 | CA | 8:15 AM | TV sample point | 2156482 | ABSENT | ABSENT | 0.88 | |
| 09-Aug-23 | CA | 7:40 AM | BD sample point | 2156479 | ABSENT | ABSENT | 0.88 | |
| 09-Aug-23 | CA | 7:50 AM | TV sample point | 2156478 | ABSENT | ABSENT | 0.95 | |
| 16-Aug-23 | CA | 7:25 AM | BD sample point | 2156474 | ABSENT | ABSENT | 0.90 | |
| 16-Aug-23 | CA | 7:30 AM | TV sample point | 2156475 | ABSENT | ABSENT | 0.99 | |
| 23-Aug-23 | CA | 8:05 AM | BD sample point | 2156473 | ABSENT | ABSENT | 0.84 | |
| 23-Aug-23 | CA | 8:50 AM | TV sample point | 2156472 | ABSENT | ABSENT | 0.86 | |
| 30-Aug-23 | CA | 7:30 AM | BD sample point | 2156467 | ABSENT | ABSENT | 0.91 | |
| 30-Aug-23 | CA | 7:50 AM | TV sample point | 2156466 | ABSENT | ABSENT | 1.01 | |
| 06-Sep-23 | CA | 7:45 AM | TV sample point | 2156464 | ABSENT | ABSENT | 0.98 | 8 |
| 06-Sep-23 | CA | 8:00 AM | BD sample point | 2156465 | ABSENT | ABSENT | 0.92 | |
| 13-Sep-23 | CA | 8:40 AM | BD sample point | 2156463 | ABSENT | ABSENT | 0.99 | |
| 13-Sep-23 | CA | 8:45 AM | TV sample point | 2156462 | ABSENT | ABSENT | 1.03 | |
| 20-Sep-23 | CA | 8:00 AM | BD sample point | 2156460 | ABSENT | ABSENT | 1.15 | |
| 20-Sep-23 | CA | 8:05 AM | TV sample point | 2156461 | ABSENT | ABSENT | 1.28 | |
| 27-Sep-23 | CA | 8:20 AM | BD sample point | 2156458 | ABSENT | ABSENT | 0.98 | |
| 27-Sep-23 | CA | 8:30 AM | TV sample point | 2156459 | ABSENT | ABSENT | 0.99 | |
| 04-Oct-23 | CA | 8:32 AM | BD sample point | 2156456 | ABSENT | ABSENT | 0.99 | 8 |
| 04-Oct-23 | CA | 8:28 AM | TV sample point | 2156457 | ABSENT | ABSENT | 1.03 | |
| 11-Oct-23 | CA | 9:00 AM | BD sample point | 2156454 | ABSENT | ABSENT | 0.92 | |
| 11-Oct-23 | CA | 9:05 AM | TV sample point | 2156455 | ABSENT | ABSENT | 0.88 | |
| 18-Oct-23 | CA | 9:05 AM | BD sample point | 2156452 | ABSENT | ABSENT | 0.95 | |
| 18-Oct-23 | CA | 9:10 AM | TV sample point | 2156453 | ABSENT | ABSENT | 0.94 | |
| 25-Oct-23 | DM | 8:45 AM | WTP - Black Diamond Dist. Header | 2156151 | ABSENT | ABSENT | 0.90 | |
| 25-Oct-23 | DM | 9:00 AM | WTP: TV (Distribution Header) | 2156451 | ABSENT | ABSENT | 0.94 | |
| 01-Nov-23 | CA | 9:40 AM | TV sample point | 2156198 | ABSENT | ABSENT | 0.94 | 10 |
| 01-Nov-23 | CA | 9:45 AM | BD sample point | 2156199 | ABSENT | ABSENT | 0.88 | |
| 08-Nov-23 | CA | 8:10 AM | BD sample point | 2156200 | ABSENT | ABSENT | 0.97 | |
| 08-Nov-23 | CA | 8:15 AM | TV sample point | 2156197 | ABSENT | ABSENT | 1.01 | |
| 15-Nov-23 | CA | 9:05 AM | BD sample point | 2156196 | ABSENT | ABSENT | 0.93 | |
| 15-Nov-23 | CA | 9:10 AM | TV sample point | 2156195 | ABSENT | ABSENT | 0.96 | |
| 22-Nov-23 | CA | 7:00 AM | BD sample point | 2156193 | ABSENT | ABSENT | 0.90 | |
| 22-Nov-23 | CA | 7:05 AM | TV sample point | 2156194 | ABSENT | ABSENT | 0.92 | |
| 29-Nov-23 | CA | 7:10 AM | TV sample point | 2156192 | ABSENT | ABSENT | 1.00 | |
| 29-Nov-23 | DM | 7:15 AM | BD sample point | 2156191 | ABSENT | ABSENT | 0.98 | |
| 06-Dec-23 | CA | 7:00 AM | BD sample point | 2641201 | ABSENT | ABSENT | 0.96 | 8 |
| 06-Dec-23 | CA | 7:05 AM | TV sample point | 2641202 | ABSENT | ABSENT | 0.97 | |
| 13-Dec-23 | CA | 7:50 AM | BD sample point | 2641249 | ABSENT | ABSENT | 0.94 | |
| 13-Dec-23 | CA | 7:55 AM | TV sample point | 2641250 | ABSENT | ABSENT | 0.96 | |
| 20-Dec-23 | DM | 7:15 AM | BD sample point | 2641204 | ABSENT | ABSENT | 1.04 | |
| 20-Dec-23 | CA | 7:15 AM | TV sample point | 2641203 | ABSENT | ABSENT | 1.01 | |
| 27-Dec-23 | CA | 7:15 AM | BD sample point | 2641248 | ABSENT | ABSENT | 0.97 | |
| 27-Dec-23 | CA | 7:18 AM | TV sample point | 2641247 | ABSENT | ABSENT | 1.01 | |
| | | | | | | **Min** | **0.80** | |
| | | | | | | **Avg.** | **0.98** | |
| | | | | | | **Max** | **1.36** | |

**Please note that all samples collected are obtained from within the WTP for water leaving to BD (East Diamond Valley) and TV (West Diamond Valley).**
**Sampling is being completed to verify water leaving the facility does not contain E-coli or Coliforms. This is additional sampling and is not required by the approval.**