



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2025-01-01	587	889	1476	12	1488	1765	277	0	928	846	1774	95.0
2025-01-02	584	911	1495	12	1507	2219	712	0	930	845	1775	95.1
2025-01-03	586	913	1499	11	1510	1908	399	0	927	848	1775	94.9
2025-01-04	586	948	1535	11	1545	1931	386	0	928	823	1751	95.0
2025-01-05	620	959	1579	17	1596	2215	619	0	928	805	1733	95.0
2025-01-06	582	971	1553	16	1569	2088	520	0	927	806	1733	94.9
2025-01-07	585	942	1527	14	1541	1929	388	0	928	805	1733	94.7
2025-01-08	579	947	1526	12	1538	2065	528	0	928	804	1732	95.0
2025-01-09	586	956	1542	17	1559	2088	530	0	927	806	1733	94.4
2025-01-10	584	947	1530	13	1544	1930	387	0	928	804	1732	94.7
2025-01-11	573	934	1507	13	1520	2144	625	0	928	828	1756	94.7
2025-01-12	603	943	1546	11	1557	1982	426	0	928	841	1769	94.4
2025-01-13	600	956	1557	13	1569	2097	528	0	1019	842	1861	94.4
2025-01-14	601	960	1561	15	1576	1998	422	0	1098	839	1937	94.9
2025-01-15	579	966	1545	15	1560	2005	445	0	1096	835	1931	95.0
2025-01-16	576	945	1521	15	1536	2069	533	0	1098	836	1934	95.4
2025-01-17	595	937	1532	14	1546	2139	593	0	1098	833	1931	95.2
2025-01-18	590	938	1527	13	1541	1953	413	0	1097	816	1913	95.1
2025-01-19	606	944	1550	14	1564	1968	404	0	1097	803	1900	95.2
2025-01-20	617	947	1565	15	1579	1942	363	0	1097	802	1899	95.4
2025-01-21	609	952	1561	13	1574	2296	722	0	1097	804	1901	95.7
2025-01-22	599	943	1542	14	1556	1864	309	0	1098	803	1901	95.6
2025-01-23	630	933	1563	15	1578	2085	507	0	1098	803	1901	95.8
2025-01-24	623	946	1569	14	1583	2057	474	0	1096	803	1899	95.7
2025-01-25	600	955	1555	12	1567	2100	533	0	1097	821	1918	95.8
2025-01-26	630	955	1584	12	1597	2287	691	0	1098	831	1929	95.9
2025-01-27	590	962	1552	14	1566	2160	594	0	1097	829	1926	96.0
2025-01-28	561	951	1512	14	1526	1801	275	0	1067	805	1872	96.1
2025-01-29	577	944	1521	16	1537	2024	487	0	1026	812	1838	96.4
2025-01-30	608	944	1552	11	1563	2181	618	0	953	785	1738	96.2
2025-01-31	587	949	1536	12	1548	2036	488	0	929	803	1732	95.8
Min	561	889	1476	10.53	1488	1765		0	927	785	1732	94.4
Avg	595	945	1539	13.49	1553	2043	490	0	1016	818	1834	95.3
Max	630	971	1584	16.68	1597	2296		0	1098	848	1937	96.4
Total m3	18435	29282	47717	418.24	48135	63326	15191	0	31491	25364	56855	

↑
Cells will highlight red if volume is if above
3000 m3/ per day for DV.

23.99%
Loss

Full Level	186,560	100.00%
End of Month	178,724	95.8%
Average Month Volume	177,739	