



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2025-04-01	644	1277	1921	7.06	1928	2012	84	161	931	1121	2213	90.9
2025-04-02	617	1370	1987	7.57	1995	2585	590	163	930	1121	2214	91.3
2025-04-03	608	1368	1976	7.64	1984	2147	163	162	930	1121	2213	91.2
2025-04-04	603	1406	2009	8.02	2017	2223	206	170	898	1121	2189	91.0
2025-04-05	595	1433	2028	6.54	2035	2690	655	166	862	1121	2149	90.8
2025-04-06	659	1432	2091	5.19	2096	2542	446	166	861	1121	2148	90.8
2025-04-07	608	1431	2039	9.71	2049	2541	492	166	862	1122	2150	90.3
2025-04-08	648	1404	2052	7.53	2060	2366	306	229	897	1089	2215	90.6
2025-04-09	639	1400	2039	8.81	2048	2369	321	253	904	1078	2235	90.3
2025-04-10	621	1388	2009	8.18	2017	2040	23	249	905	1079	2233	89.7
2025-04-11	592	1410	2002	6.83	2009	2107	98	248	904	1078	2230	89.8
2025-04-12	654	1393	2047	4.05	2051	2677	626	250	905	1078	2233	90.3
2025-04-13	654	1380	2034	7.51	2042	2047	5	256	872	1070	2198	90.1
2025-04-14	632	1399	2031	8.72	2040	2354	314	250	760	1009	2019	89.7
2025-04-15	608	1390	1998	8.43	2006	2285	279	245	776	1036	2057	89.6
2025-04-16	593	1373	1966	7.67	1974	2636	662	255	799	1035	2089	88.9
2025-04-17	639	1369	2008	7.41	2015	2104	89	264	819	1035	2118	88.9
2025-04-18	637	1363	2000	7.41	2007	2535	528	259	818	1100	2177	87.9
2025-04-19	674	1355	2029	7.02	2036	2414	378	266	819	1111	2196	88.6
2025-04-20	633	1351	1984	8.94	1993	2108	115	272	818	1106	2196	87.4
2025-04-21	600	1344	1944	5.18	1949	3234	1285	266	818	1237	2321	88.1
2025-04-22	617	1344	1961	6.81	1968	2760	792	274	818	1293	2385	88.2
2025-04-23	602	1342	1944	5.41	1949	2672	723	275	818	1294	2387	87.8
2025-04-24	645	1353	1998	7.68	2006	2464	458	271	818	1292	2381	88.0
2025-04-25	649	1358	2007	9.36	2016	2873	857	271	818	1089	2178	87.5
2025-04-26	649	1360	2009	5.88	2015	2553	538	271	818	1294	2383	88.1
2025-04-27	661	1365	2026	5.66	2032	2432	400	266	854	1294	2414	88.2
2025-04-28	594	1377	1971	6.84	1978	2233	255	266	862	1323	2451	88.0
2025-04-29	618	1343	1961	7.42	1968	2164	196	267	862	1320	2449	88.7
2025-04-30	632	1352	1984	7.35	1991	2413	422	263	862	1331	2456	88.9
Min	592	1277	1921	4.05	1928	2012		161	760	1009	2019	87.4
Avg	628	1374	2002	7.26	2009	2419	410	238	854	1151	2243	89.3
Max	674	1433	2091	9.71	2096	3234		275	931	1331	2456	91.3
Total m3	18826	41230	60056	217.82	60274	72580	12306	7140	25618	34519	67277	

↑
Cells will highlight red if volume is if above
3000 m3/ per day for DV.

16.96%
Loss

Full Level
End of Month
Average Month Volume

186,403
165,712
166,495

100.00%
88.9%