



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2025-08-01	799	1270	2069	8	2077	2500	423	187	1846	0	2033	93.1
2025-08-02	778	1253	2031	6	2037	2307	270	161	1810	0	1971	92.3
2025-08-03	761	1247	2008	9	2017	2354	337	158	1929	0	2087	92.2
2025-08-04	776	1240	2016	8	2024	2525	501	174	1790	0	1964	92.1
2025-08-05	745	1236	1981	21	2002	2225	223	155	1804	0	1959	91.6
2025-08-06	761	1280	2041	46	2087	2753	666	177	1772	0	1949	91.3
2025-08-07	838	1276	2114	6	2120	2454	334	171	1638	0	1809	90.2
2025-08-08	763	1236	1999	6	2005	2224	219	152	1760	0	1912	90.0
2025-08-09	759	1236	1995	14	2009	2354	345	169	1739	0	1908	90.0
2025-08-10	794	1312	2106	20	2126	2371	245	167	1696	0	1863	89.7
2025-08-11	790	1341	2131	47	2178	2496	318	161	1682	0	1843	89.1
2025-08-12	820	1307	2127	9	2136	2493	357	169	1642	0	1811	88.6
2025-08-13	854	1328	2182	8	2190	2576	386	166	1594	0	1760	87.9
2025-08-14	881	1284	2165	6	2171	2595	424	162	1595	0	1757	87.4
2025-08-15	800	1268	2068	7	2075	2313	238	166	1580	518	2264	86.8
2025-08-16	784	1275	2059	65	2124	2302	178	162	1551	1980	3693	90.1
2025-08-17	840	1324	2164	10	2174	2534	360	163	1538	1979	3680	91.3
2025-08-18	932	1335	2267	8	2275	2592	317	161	1508	1882	3551	92.2
2025-08-19	826	1291	2117	8	2125	2317	192	168	1476	1808	3452	92.5
2025-08-20	853	1312	2165	9	2174	2444	270	161	1423	1809	3393	93.1
2025-08-21	870	1316	2186	10	2196	2694	498	162	1422	1808	3392	93.9
2025-08-22	836	1304	2140	8	2148	2326	178	160	1422	1808	3390	94.6
2025-08-23	811	1324	2135	8	2143	2581	438	166	1390	1808	3364	95.3
2025-08-24	850	1387	2237	41	2278	2414	136	164	1335	1808	3307	95.7
2025-08-25	868	1405	2273	41	2314	2500	186	163	1335	1747	3245	96.4
2025-08-26	957	1342	2299	10	2309	2512	203	161	1336	1722	3219	96.6
2025-08-27	885	1380	2265	42	2307	2560	253	161	1336	1722	3219	97.2
2025-08-28	983	1398	2381	17	2398	2657	259	153	1336	1723	3212	97.3
2025-08-29	916	1392	2308	13	2321	2898	577	189	1299	1722	3210	98.0
2025-08-30	937	1379	2316	11	2327	2530	203	191	1292	1598	3081	98.2
2025-08-31	833	1318	2151	12	2163	2352	189	190	1292	1550	3032	98.4
Min	745	1236	1981	5.57	2002	2224	136	152	1292	0	1757	86.8
Avg	836	1310	2145	17.18	2162	2476	314	167	1554	935	2656	92.7
Max	983	1405	2381	64.59	2398	2898	666	191	1929	1980	3693	98.4
Total m3	25901	40596	66497	532.52	67030	76753	9723	5170	48168	28992	82330	

↑
Cells will highlight red if volume is above 3000 m3/ per day for DV.

12.67%
Loss

Full Level
End of Month
Average Month Volume

186,403
183,421
172,760

100.00%
98.4%