



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2025-07-01	742	605	1347	14	1361	1541	180	184	1551	0	1735	89.1
2025-07-02	786	1835	2621	10	2631	3175	544	201	1381	0	1582	88.0
2025-07-03	843	1668	2511	14	2525	2912	387	189	1378	0	1567	87.7
2025-07-04	740	1365	2105	13	2118	2488	370	189	1379	0	1568	86.4
2025-07-05	667	1258	1925	20	1945	2289	344	174	1378	1	1553	85.7
2025-07-06	687	1280	1967	11	1978	2423	445	35	1378	0	1413	84.9
2025-07-07	784	1291	2075	12	2087	2491	404	36	1378	1109	2523	84.0
2025-07-08	793	1321	2114	18	2132	2459	327	39	1377	2153	3569	87.3
2025-07-09	880	1778	2658	11	2669	3116	447	33	1378	2151	3562	88.4
2025-07-10	878	1337	2215	9	2224	2986	762	33	1378	2154	3565	89.0
2025-07-11	811	1252	2063	7	2070	2372	302	33	1379	2152	3564	89.5
2025-07-12	841	1323	2164	14	2178	2634	456	30	1378	2150	3558	90.2
2025-07-13	840	1364	2204	13	2217	2496	279	34	1368	2152	3554	91.0
2025-07-14	761	1215	1976	8	1984	2298	314	28	1355	2151	3534	91.7
2025-07-15	758	1172	1930	9	1939	2375	436	136	1378	2152	3666	94.2
2025-07-16	793	1241	2034	8	2042	2474	432	188	1378	2152	3718	95.5
2025-07-17	809	1239	2048	6	2054	2325	271	188	1378	1446	3012	96.5
2025-07-18	771	1196	1967	5	1972	2406	434	191	1378	0	1569	94.2
2025-07-19	706	1174	1880	10	1890	2153	263	177	1448	0	1625	93.4
2025-07-20	718	1196	1914	6	1920	2341	421	179	1580	0	1759	93.6
2025-07-21	729	1189	1918	8	1926	2362	436	173	1662	0	1835	93.6
2025-07-22	786	1150	1936	6	1942	2217	275	163	1824	0	1987	94.2
2025-07-23	785	1192	1977	21	1998	2352	354	191	1809	0	2000	94.4
2025-07-24	779	1240	2019	8	2027	2402	375	170	1805	0	1975	94.1
2025-07-25	808	1213	2021	17	2038	2342	304	152	1990	0	2142	93.8
2025-07-26	730	1203	1933	6	1939	2450	511	191	1841	0	2032	94.0
2025-07-27	782	1224	2006	8	2014	2056	42	162	1802	0	1964	93.2
2025-07-28	807	1195	2002	25	2027	2381	354	161	1932	0	2093	93.6
2025-07-29	803	1195	1998	30	2028	2325	297	183	1789	0	1972	93.9
2025-07-30	788	1236	2024	8	2032	2688	656	166	1810	0	1976	93.4
2025-07-31	826	1292	2118	8	2126	2425	299	149	1992	0	2141	93.1
Min	667	605	1347	5.25	1361	1541		28	1355	0	1413	84.0
Avg	782	1272	2054	11.63	2066	2444	378	134	1556	707	2397	91.3
Max	880	1835	2658	30.40	2669	3175		201	1992	2154	3718	96.5
Total m3	24234	39439	63673	360.49	64033	75754	11721	4158	48232	21923	74313	

↑
Cells will highlight red if volume is above
3000 m3/ per day for DV.

15.47%
Loss

Full Level
End of Month
Average Month Volume

186,403
173,541
170,264

100.00%
93.1%