



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2025-06-01	753	1491	2244	18.88	2263	2414	151	216	1293	864	2373	89.6
2025-06-02	715	1409	2124	13.34	2137	2783	646	213	1294	863	2370	89.9
2025-06-03	690	1331	2021	15.73	2037	2301	264	209	1294	864	2367	88.9
2025-06-04	706	1355	2061	15.44	2076	2491	415	209	1292	994	2495	88.9
2025-06-05	799	1407	2206	22.09	2228	2854	626	84	1293	1122	2499	89.3
2025-06-06	806	1438	2244	24.84	2269	2791	522	46	1293	1191	2530	88.8
2025-06-07	796	1456	2252	20.55	2273	2609	336	48	1292	1341	2681	89.3
2025-06-08	868	1502	2370	16.48	2386	2671	285	44	1293	1605	2942	89.3
2025-06-09	889	1538	2427	21.27	2448	3563	1115	46	1292	1351	2689	90.2
2025-06-10	840	1528	2368	27.26	2395	2892	497	40	1318	1948	3306	89.7
2025-06-11	793	1520	2313	26.11	2339	2790	451	42	1334	2153	3529	89.6
2025-06-12	750	1443	2193	21.96	2215	2594	379	41	1334	2152	3527	90.1
2025-06-13	668	1360	2028	12.76	2041	2673	632	45	1322	2152	3519	91.0
2025-06-14	690	1335	2025	18.72	2044	2472	428	40	1292	2152	3484	91.5
2025-06-15	702	1342	2044	23.74	2068	2508	440	39	1291	2152	3482	92.3
2025-06-16	699	1345	2044	11.05	2055	2520	465	41	1281	356	1678	90.8
2025-06-17	701	1344	2045	15.49	2060	2533	473	37	1266	0	1303	89.3
2025-06-18	781	1354	2135	10.73	2146	2556	410	37	1256	0	1293	87.8
2025-06-19	760	1357	2117	15.04	2132	2430	298	39	1240	48	1327	86.5
2025-06-20	630	1229	1859	5.59	1865	2380	515	36	1222	639	1897	85.4
2025-06-21	598	1128	1726	9.94	1736	2029	293	83	1435	1292	2810	88.1
2025-06-22	643	1127	1770	9.59	1780	2131	351	200	1714	1293	3207	91.4
2025-06-23	650	1130	1780	6.97	1787	2150	363	197	1686	1296	3179	92.6
2025-06-24	666	1122	1788	12.47	1800	2156	356	190	1708	1000	2898	93.1
2025-06-25	669	1191	1860	10.91	1871	2100	229	191	1724	0	1915	91.9
2025-06-26	751	1244	1995	19.54	2015	2646	631	192	1703	0	1895	91.4
2025-06-27	674	1198	1872	10.50	1882	2240	358	187	1707	0	1894	91.0
2025-06-28	643	1184	1827	19.01	1846	2174	328	194	1667	0	1861	90.5
2025-06-29	680	1201	1881	11.43	1892	2707	815	185	1638	0	1823	90.0
2025-06-30	749	1029	1778	9.48	1787	2284	497	191	1546	0	1737	89.5

Min	598	1029	1726	5.59	1736	2029		36	1222	0	1293	85.4
Avg	725	1321	2047	15.90	2062	2515	452	112	1411	961	2484	89.9
Max	889	1538	2427	27.26	2448	3563		216	1724	2153	3529	93.1
Total m3	21758	39638	61396	476.90	61873	75442	13569	3362	42320	28826	74508	

↑
Cells will highlight red if volume is above 3000 m3/ per day for DV.

17.99%
Loss

Full Level
End of Month
Average Month Volume

186,403
166,831
167,620

100.00%
89.5%