Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2024-11-01	778	1078	1856	7	1863	2129	266	121	1075	903	2099	95.4
2024-11-02	799	1107	1906	31	1937	2242	305	121	1090	903	2114	95.5
2024-11-03	770	1122	1892	8	1900	2077	177	84	1063	943	2090	94.4
2024-11-04	796	1092	1888	7	1895	2222	327	48	1045	989	2082	95.2
2024-11-05	803	1095	1898	10	1908	2310	402	48	1077	989	2113	94.2
2024-11-06	815	1095	1910	11	1921	2228	307	48	1069	989	2105	95.1
2024-11-07	781	1095	1876	33	1909	2244	335	48	1047	989	2083	94.9
2024-11-08	780	1137	1917	7	1924	2037	113	48	1074	989	2111	95.2
2024-11-09	788	1141	1929	6	1935	2344	409	48	1057	989	2093	94.9
2024-11-10	772	1142	1914	6	1920	2182	262	102	1040	990	2132	93.9
2024-11-11	793	1148	1941	10	1951	2142	191	121	1058	989	2168	94.0
2024-11-12	783	1224	2007	7	2014	2424	410	121	1013	1048	2182	93.7
2024-11-13	782	1166	1948	5	1953	2266	313	121	1003	1075	2199	93.7
2024-11-14	810	1151	1961	6	1967	2511	544	121	1014	1074	2209	94.3
2024-11-15	779	1160	1939	36	1975	2165	190	121	1007	1074	2202	94.2
2024-11-16	795	1169	1964	7	1971	2256	285	121	1006	1075	2202	94.1
2024-11-17	756	1196	1952	8	1960	2485	525	121	1014	1074	2209	93.9
2024-11-18	828	1144	1972	8	1980	2202	222	121	1001	1074	2196	93.2
2024-11-19	838	1145	1983	11	1994	2269	275	121	1003	1075	2199	93.4
2024-11-20	796	1155	1951	9	1960	2232	272	121	995	1073	2189	93.8
2024-11-21	788	1177	1965	7	1972	2180	208	121	990	1075	2186	95.5
2024-11-22	778	1168	1946	7	1953	2253	300	121	981	1074	2176	94.1
2024-11-23	812	1184	1996	7	2003	2468	465	121	979	1074	2174	93.0
2024-11-24	778	1160	1938	9	1947	2216	269	121	982	1074	2177	93.9
2024-11-25	783	1165	1948	7	1955	2227	272	48	1021	1075	2143	93.7
2024-11-26	801	1191	1992	9	2001	2411	410	48	992	1074	2113	93.6
2024-11-27	790	1193	1983	12	1995	2269	274	48	989	1074	2110	93.4
2024-11-28	776	1195	1971	8	1979	2325	346	48	992	1074	2113	93.1
2024-11-29	794	1222	2016	7	2023	2482	459	48	995	1074	2116	93.3
2024-11-30	826	1227	2053	8	2061	2504	443	48	993	1074	2114	93.3
Min	756	1078	1856	5.20	1863	2037		48	979	903	2082	93.0
Avg	792	1155	1947	10.42	1958	2277	319	90	1022	1035	2147	94.1
Max	838	1227	2053	35.90	2061	2511		121	1090	1075	2209	95.5
Total m3	**23769**	**34644**	**58413**	**312.61**	**58726**	**68302**	9576	**2692**	**30660**	**31046**	**64398**	

↑

Cells will highlight red if volume is above 3000 m3/ per day for DV.

14.02% Loss

Full Level	**186,403**	100.00%
End of Month	**173,914**	93.3%
Average Month Volume	**175,461**	