



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2025-10-01	834	1098	1932	18	1950	2230	280	0	1126	883	2099	99.2
2025-10-02	846	1081	1927	10	1937	2176	239	0	1059	1260	2319	97.5
2025-10-03	844	1120	1964	10	1974	2211	237	0	1033	1255	2288	97.3
2025-10-04	848	1106	1954	10	1964	2249	285	0	998	1256	2254	97.1
2025-10-05	801	1078	1879	7	1886	2157	271	0	1123	1250	2373	97.7
2025-10-06	766	1084	1850	13	1863	2136	273	0	1127	1246	2373	98.1
2025-10-07	827	1130	1957	22	1979	2266	287	0	1060	1250	2310	98.6
2025-10-08	842	1139	1981	8	1989	2414	425	0	1133	1250	2383	98.5
2025-10-09	854	1063	1917	9	1926	2075	149	0	1132	1250	2382	98.7
2025-10-10	906	1062	1968	6	1974	2203	229	0	1059	1249	2308	98.6
2025-10-11	794	1093	1887	13	1900	2231	331	0	1130	1249	2379	98.5
2025-10-12	789	1075	1864	7	1871	2136	265	0	1104	1235	2339	99.1
2025-10-13	811	1083	1894	8	1902	2265	363	0	1047	1230	2277	99.0
2025-10-14	792	1067	1859	9	1868	2172	304	0	1132	1063	2195	99.2
2025-10-15	838	1058	1896	7	1903	2099	196	0	1103	860	1963	99.1
2025-10-16	837	1059	1896	7	1903	2097	194	0	1051	860	1911	98.4
2025-10-17	811	1067	1878	41	1919	2394	475	41	1133	861	1994	97.7
2025-10-18	801	1097	1898	11	1909	2220	311	0	1104	861	1965	98.7
2025-10-19	837	1120	1957	7	1964	2128	164	0	1053	861	1914	97.9
2025-10-20	806	1099	1905	9	1914	2189	275	0	1127	860	1987	97.1
2025-10-21	793	1078	1871	7	1878	2114	236	0	1104	860	1964	96.9
2025-10-22	765	1059	1824	12	1836	2192	356	0	1105	860	1965	96.9
2025-10-23	823	1052	1875	10	1885	2161	276	0	1127	860	1987	96.5
2025-10-24	777	1072	1849	8	1857	2082	225	0	1063	860	1923	96.7
2025-10-25	775	1066	1841	7	1848	2196	348	0	1093	861	1954	96.6
2025-10-26	819	1092	1911	6	1917	2474	557	0	1126	861	1987	96.4
2025-10-27	776	1079	1855	8	1863	2152	289	0	1066	860	1926	96.0
2025-10-28	824	1117	1941	8	1949	2124	175	0	1096	860	1956	95.3
2025-10-29	788	1082	1870	9	1879	2164	285	162	1051	861	2074	95.3
2025-10-30	792	1065	1857	9	1866	2007	141	121	1057	861	2039	95.5
2025-10-31	784	1075	1859	7	1866	2346	480	121	1088	891	2100	94.9
Min	765	1052	1824	5.79	1836	2007		0	998	860	1911	94.9
Avg	813	1084	1897	10.45	1908	2195	288	13	1091	1019	2123	97.5
Max	906	1139	1981	40.52	1989	2474		162	1133	1260	2383	99.2
Total m3	25199	33616	58815	323.98	59139	68060	8921	404	33810	31584	65798	

↑
Cells will highlight red if volume is above
3000 m3/ per day for DV.

13.11%
Loss

Full Level
End of Month
Average Month Volume

186,403
176,896
181,773

100.00%
94.9%