



## Sheep River Regional Utility Corporation

### Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2025-09-01	905	1443	2348	85	2433	2779	346	196	1244	1490	2930	98.9
2025-09-02	842	1348	2190	12	2202	2468	266	192	1206	1464	2862	98.6
2025-09-03	944	1362	2306	15	2321	2717	396	191	1206	1464	2861	98.7
2025-09-04	940	1341	2281	21	2302	2587	285	189	1206	1463	2858	99.0
2025-09-05	1062	1347	2409	13	2422	2652	230	189	1206	1465	2860	98.9
2025-09-06	958	1368	2326	17	2343	2645	302	186	1206	1464	2856	99.1
2025-09-07	947	1395	2342	13	2355	2795	440	188	1197	1464	2849	99.4
2025-09-08	805	1373	2178	12	2190	2449	259	189	1178	1414	2781	99.8
2025-09-09	746	1305	2051	18	2069	2298	229	185	1180	1379	2744	99.7
2025-09-10	782	1331	2113	61	2174	2434	260	183	1180	1378	2741	100.0
2025-09-11	818	1362	2180	10	2190	2668	478	84	460	1014	1558	100.0
2025-09-12	792	1369	2161	12	2173	2405	232	50	862	1382	2294	99.3
2025-09-13	775	1352	2127	9	2136	2440	304	99	1180	1378	2657	98.8
2025-09-14	815	1374	2189	8	2197	2620	423	159	1180	1377	2716	99.2
2025-09-15	791	1427	2218	10	2228	2425	197	155	1180	1338	2673	99.5
2025-09-16	796	1349	2145	38	2183	2352	169	152	1196	1292	2640	99.1
2025-09-17	848	1401	2249	11	2260	2505	245	151	1205	1293	2649	99.4
2025-09-18	857	1374	2231	13	2244	2612	368	117	1182	1292	2591	99.6
2025-09-19	822	1367	2189	7	2196	2498	302	78	1163	1292	2533	99.5
2025-09-20	842	1398	2240	8	2248	2525	277	78	1163	1293	2534	99.4
2025-09-21	857	1416	2273	7	2280	2517	237	79	1162	1292	2533	99.4
2025-09-22	841	1328	2169	9	2178	2489	311	78	1162	1292	2532	99.1
2025-09-23	845	1107	1952	36	1988	2238	250	80	1162	1294	2536	99.2
2025-09-24	809	1118	1927	10	1937	2232	295	79	1163	1295	2537	99.5
2025-09-25	842	1076	1918	47	1965	2238	273	83	1162	1295	2540	99.6
2025-09-26	813	1079	1892	31	1923	2344	421	78	1162	1278	2518	99.7
2025-09-27	819	1085	1904	3	1907	2041	134	85	1102	1255	2442	99.8
2025-09-28	850	1070	1920	2	1922	2179	257	79	1076	1259	2414	99.5
2025-09-29	812	1116	1928	16	1944	2168	224	32	1041	1254	2327	99.8
2025-09-30	828	1050	1878	65	1943	2397	454	0	1058	345	1403	100.0

<b>Min</b>	746	1050	1878	2.24	1907	2041		0	460	345	1403	98.6
<b>Avg</b>	847	1294	2141	20.67	2162	2457	295	123	1134	1308	2566	99.4
<b>Max</b>	1062	1443	2409	84.98	2433	2795		196	1244	1490	2930	100.0
<b>Total m3</b>	<b>25402</b>	<b>38831</b>	<b>64233</b>	<b>619.95</b>	<b>64853</b>	<b>73717</b>	<b>8864</b>	<b>3684</b>	<b>34030</b>	<b>39255</b>	<b>76969</b>	

↑  
Cells will highlight red if volume is above  
3000 m3/ per day for DV.

12.02%  
Loss

Full Level  
End of Month  
Average Month Volume

**186,403**  
**186,403**  
**185,254**

100.00%  
100.00%