



## Sheep River Regional Utility Corporation

### Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2025-04-01	872	1020	1892	10	1902	2124	222	139	1131	1217	2487	88.7
2025-04-02	848	985	1833	8	1841	2008	168	137	1118	1207	2462	88.8
2025-04-03	859	976	1835	7	1842	2093	251	143	1045	1207	2395	89.3
2025-04-04	844	976	1820	8	1828	2072	244	136	995	1206	2337	89.2
2025-04-05	866	978	1844	10	1854	2193	339	134	1012	1208	2354	88.4
2025-04-06	879	987	1865	7	1873	2106	234	134	1029	1207	2370	89.6
2025-04-07	822	975	1797	9	1806	2218	412	134	1020	1208	2362	89.2
2025-04-08	867	1007	1874	10	1884	2118	234	132	1020	1207	2359	90.2
2025-04-09	863	1028	1891	9	1900	2055	155	133	1021	1207	2361	89.8
2025-04-10	863	1038	1901	8	1909	2174	265	131	1017	1207	2355	92.3
2025-04-11	838	1014	1852	8	1860	2033	173	130	1011	1207	2348	91.7
2025-04-12	888	1012	1900	10	1910	2126	216	129	1012	1206	2347	90.9
2025-04-13	846	1032	1878	8	1886	2252	366	127	1012	1208	2347	91.7
2025-04-14	875	1003	1878	8	1886	2012	126	128	1012	1078	2218	90.5
2025-04-15	860	1018	1878	8	1886	2253	367	117	982	1035	2134	90.3
2025-04-16	850	997	1847	8	1855	2111	257	125	1062	1027	2214	83.0
2025-04-17	860	1004	1864	6	1870	2161	291	162	1056	997	2215	80.8
2025-04-18	854	1016	1870	7	1877	2010	133	132	1056	1013	2201	80.9
2025-04-19	905	1041	1946	8	1954	2278	324	132	1055	1013	2200	80.9
2025-04-20	824	1077	1901	7	1908	2253	345	136	1025	911	2072	80.9
2025-04-21	847	1059	1906	8	1914	2143	229	135	1040	369	1544	80.7
2025-04-22	876	1031	1907	9	1916	2198	282	131	1091	3	1225	79.8
2025-04-23	872	1003	1875	9	1884	1999	115	126	1175	537	1838	79.1
2025-04-24	871	996	1866	8	1875	2196	322	128	1228	864	2220	79.1
2025-04-25	888	985	1873	8	1881	2201	320	127	1203	863	2193	79.3
2025-04-26	924	981	1905	8	1913	2139	226	125	1203	863	2191	79.5
2025-04-27	880	1008	1888	9	1897	2086	189	72	1196	971	2239	79.5
2025-04-28	870	994	1864	8	1872	2087	216	35	1186	1078	2299	79.4
2025-04-29	886	1023	1909	7	1916	2216	300	35	1174	1077	2286	79.3
2025-04-30	880	1030	1910	9	1919	2190	271	26	1164	1079	2269	79.4

<b>Min</b>	822	975	1797	5.83	1806	1999		26	982	3	1225	79.1
<b>Avg</b>	866	1010	1876	8.18	1884	2137	253	120	1078	1016	2215	85.1
<b>Max</b>	924	1077	1946	10.10	1954	2278		162	1228	1217	2487	92.3
<b>Total m3</b>	<b>25978</b>	<b>30292</b>	<b>56270</b>	<b>245.52</b>	<b>56516</b>	<b>64105</b>	<b>7590</b>	<b>3611</b>	<b>32351</b>	<b>30479</b>	<b>66441</b>	

↑  
Cells will highlight red if volume is more than 3000 m3 per day for DV.

11.84%  
Loss

Full Level  
End of Month  
Average Month Volume

**186,403**  
**148,004**  
**158,579**

100.00%  
79.4%