



## Sheep River Regional Utility Corporation

### Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2026-02-01	910	1491	2401	7	2408	2787	379	128	966	1246	2340	90.4
2026-02-02	878	1475	2353	10	2363	2582	219	122	1028	1247	2397	89.7
2026-02-03	860	1469	2329	8	2337	2537	200	127	1052	1300	2479	89.9
2026-02-04	904	1475	2379	9	2388	2671	283	125	1053	1332	2510	90.1
2026-02-05	868	1496	2364	9	2373	2713	340	125	1051	1331	2507	89.9
2026-02-06	882	1458	2340	10	2350	2567	217	123	1079	1332	2534	89.8
2026-02-07	856	1466	2322	10	2332	2623	291	124	1096	1331	2551	91.1
2026-02-08	878	1465	2343	10	2353	2654	301	125	1096	1332	2553	91.8
2026-02-09	901	1471	2372	15	2387	2683	296	129	1128	1332	2589	90.2
2026-02-10	874	1456	2330	11	2341	2723	382	118	1140	1332	2590	90.6
2026-02-11	902	1457	2359	9	2368	2706	338	117	1140	1330	2587	90.0
2026-02-12	892	1456	2348	18	2366	2659	293	120	1121	1352	2593	90.2
2026-02-13	872	1444	2316	12	2328	2525	197	114	1063	1333	2510	90.5
2026-02-14	819	1464	2283	13	2296	2584	288	116	1075	1332	2523	90.5
2026-02-15	810	1480	2290	10	2300	2643	343	115	1074	1331	2520	90.6
2026-02-16	847	1459	2306	8	2314	2719	405	110	1076	1331	2517	90.6
2026-02-17	823	1443	2266	9	2275	2653	378	111	1084	1333	2528	90.2
2026-02-18	831	1471	2302	9	2311	2600	289	129	1083	1330	2542	89.9
2026-02-19	863	1468	2331	11	2342	2668	326	130	1077	1333	2540	90.2
2026-02-20	826	1460	2286	11	2297	2598	301	134	971	1332	2437	89.1
2026-02-21	835	1459	2294	10	2304	2510	206	128	1010	1331	2469	89.2
2026-02-22	846	1468	2314	11	2325	2757	432	129	1009	1331	2469	89.9
2026-02-23	865	1463	2328	12	2340	2742	402	124	1040	1332	2496	90.6
2026-02-24	832	1460	2292	9	2301	2547	246	127	1052	1332	2511	89.1
2026-02-25	822	1498	2320	11	2331	2646	315	126	1052	1332	2510	90.1
2026-02-26	800	1505	2305	51	2356	2518	162	127	1052	1332	2511	89.3
2026-02-27	829	1496	2325	13	2338	2609	271	124	1053	1331	2508	90.6
2026-02-28	817	1479	2296	6	2302	2552	250	124	1052	1331	2507	90.0

<b>Min</b>	800	1443	2266	6.01	2275	2510		110	966	1246	2340	89.1
<b>Avg</b>	855	1470	2325	11.90	2337	2635	298	123	1063	1325	2512	90.1
<b>Max</b>	910	1505	2401	50.70	2408	2787		134	1140	1352	2593	91.8
<b>Total m3</b>	<b>23941</b>	<b>41152</b>	<b>65093</b>	<b>333.29</b>	<b>65426</b>	<b>73776</b>	<b>8350</b>	<b>3451</b>	<b>29773</b>	<b>37104</b>	<b>70328</b>	

↑  
Cells will highlight red if volume is more than 3000 m3 per day for DV.

11.32%  
Loss

Full Level  
End of Month  
Average Month Volume

**186,403**  
**167,763**  
**168,036**

100.00%  
90.0%