



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2026-01-01	813	1322	2135	11	2146	2422	276	129	1061	1159	2349	93.2
2026-01-02	837	1368	2205	7	2212	2641	429	126	1061	1161	2348	92.4
2026-01-03	828	1369	2197	10	2207	2483	276	128	1088	1161	2377	92.5
2026-01-04	857	1391	2248	10	2258	2632	374	125	1072	1160	2357	91.4
2026-01-05	832	1394	2226	13	2239	2539	300	119	1062	1160	2341	92.2
2026-01-06	797	1376	2173	28	2201	2392	191	123	1095	1188	2406	92.5
2026-01-07	767	1370	2137	12	2149	2655	506	124	1091	1203	2418	93.2
2026-01-08	805	1405	2210	10	2220	2480	260	118	1057	1203	2378	92.3
2026-01-09	807	1405	2212	11	2223	2518	295	118	1087	1203	2408	92.3
2026-01-10	797	1387	2184	9	2193	2594	401	119	1076	1203	2398	91.5
2026-01-11	811	1413	2224	8	2232	2589	357	116	1045	1202	2363	91.5
2026-01-12	784	1417	2201	11	2212	2415	203	133	1078	1204	2415	92.0
2026-01-13	798	1391	2189	8	2197	2482	285	138	1083	1202	2423	92.6
2026-01-14	900	1415	2315	9	2324	2767	443	133	1056	1204	2393	92.6
2026-01-15	837	1393	2230	11	2241	2485	244	139	1094	1203	2436	92.1
2026-01-16	816	1441	2257	11	2268	2581	313	146	1084	1212	2442	90.7
2026-01-17	783	1438	2221	7	2228	2528	300	138	1078	1221	2437	91.3
2026-01-18	866	1422	2288	11	2299	2636	337	129	1095	1220	2444	90.8
2026-01-19	807	1402	2209	11	2220	2493	273	129	1140	1220	2489	90.2
2026-01-20	786	1385	2171	12	2183	2447	264	126	1140	1221	2487	91.8
2026-01-21	788	1394	2182	11	2193	2647	454	127	1107	1238	2472	92.0
2026-01-22	807	1387	2194	11	2205	2350	145	124	1091	1246	2461	92.0
2026-01-23	814	1378	2192	9	2201	2557	356	125	1049	1246	2420	92.2
2026-01-24	806	1396	2202	11	2213	2521	308	122	1030	1246	2398	91.2
2026-01-25	836	1417	2253	8	2261	2693	432	125	999	1246	2370	91.7
2026-01-26	797	1439	2236	10	2246	2530	284	122	965	1245	2332	90.6
2026-01-27	821	1417	2238	11	2249	2540	291	122	966	1247	2335	91.0
2026-01-28	848	1412	2260	8	2268	2628	360	123	965	1246	2334	91.1
2026-01-29	888	1421	2309	12	2321	2521	200	123	965	1246	2334	90.2
2026-01-30	906	1443	2349	10	2359	2688	329	125	965	1246	2336	89.5
2026-01-31	895	1476	2371	8	2379	2601	222	127	965	1245	2337	90.3

Min	767	1322	2135	6.92	2146	2350		116	965	1159	2332	89.5
Avg	824	1403	2226	10.62	2237	2550	313	126	1055	1213	2395	91.6
Max	906	1476	2371	27.53	2379	2767		146	1140	1247	2489	93.2
Total m3	25534	43484	69018	329.37	69347	79055	9708	3921	32710	37607	74238	

↑
Cells will highlight red if volume is if above
3000 m3/ per day for DV.

12.28%
Loss

Full Level
End of Month
Average Month Volume

186,403
168,322
170,823

100.00%
90.3%