



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2026-03-01	830	1525	2355	10	2365	2953	588	124	1045	1331	2500	90.5
2026-03-02	853	1648	2501	8	2509	2712	203	120	1035	1324	2479	90.6
2026-03-03	812	1613	2425	9	2434	2725	291	140	1035	1313	2488	90.3
2026-03-04	817	1589	2406	8	2414	2709	295	141	1035	1313	2489	88.9
2026-03-05	819	1191	2010	11	2021	2311	290	140	1035	1313	2488	88.8
2026-03-06	812	1456	2268	8	2276	2529	253	140	1034	1312	2486	88.7
2026-03-07	825	1510	2335	9	2344	2720	376	140	1034	1316	2490	89.8
2026-03-08	826	1522	2348	6	2354	2708	354	129	1035	1316	2480	89.1
2026-03-09	859	1507	2366	10	2376	2617	241	137	1075	1325	2537	88.4
2026-03-10	849	1494	2343	11	2354	2597	243	137	1111	1333	2581	88.6
2026-03-11	848	1508	2356	12	2368	2643	275	136	1109	1330	2575	89.5
2026-03-12	817	1491	2308	7	2315	2592	277	131	1114	1332	2577	89.4
2026-03-13	827	1509	2336	10	2346	2711	365	131	1118	1331	2580	88.7
2026-03-14	825	1498	2323	7	2330	2583	253	130	1110	1332	2572	89.3
2026-03-15	871	1525	2396	8	2404	2770	366	130	1083	1331	2544	89.7
2026-03-16	852	1535	2387	7	2393	2813	420	129	1037	1318	2484	90.6
2026-03-17	817	1526	2343	6	2349	2540	191	129	1035	1371	2535	89.2
2026-03-18	837	1540	2377	8	2385	2603	218	129	1085	1376	2590	89.2
2026-03-19	840	1567	2407	9	2416	2759	343	128	1181	1375	2684	91.1
2026-03-20	833	1570	2403	8	2411	2643	232	127	1263	1375	2765	91.8
2026-03-21	842	1519	2361	6	2367	2724	357	125	1292	1374	2791	92.3
2026-03-22	884	1562	2446	10	2456	2722	266	129	1298	1374	2801	91.4
2026-03-23	864	1556	2420	9	2429	2817	388	124	1271	362	1757	91.4
2026-03-24	856	1523	2379	9	2388	2571	183	123	1262	406	1791	84.6
2026-03-25	887	1542	2429	8	2437	2827	390	122	1252	669	2043	87.3
2026-03-26	901	1529	2430	9	2439	2673	234	176	1180	967	2323	86.3
2026-03-27	858	1516	2374	9	2383	2822	439	174	1112	1048	2334	87.5
2026-03-28	889	1241	2130	6	2136	2307	171	134	1118	974	2226	88.4
2026-03-29	908	1174	2082	8	2090	2552	462	133	1122	983	2238	86.8
2026-03-30	917	1208	2125	9	2134	2398	264	132	1066	1100	2298	89.0
2026-03-31	886	1138	2024	8	2032	2399	367	140	1128	1227	2495	88.7
Min	812	1138	2010	6	2021	2307		120	1034	362	1757	84.6
Avg	850	1478	2329	8	2337	2647	310	134	1120	1198	2452	89.2
Max	917	1648	2501	12	2509	2953		176	1298	1376	2801	92.3
Total m3	26362	45832	72194	261	72455	82050	9595	4160	34710	37151	76021	

↑
Cells will highlight red if volume is more than 3000 m3 per day for DV.

11.69%
Loss

Full Level
End of Month
Average Month Volume

186,403
165,339
166,314

100.00%
88.7%