



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2026-05-01	892	1042	1934	8	1942	2152	210	118	1166	1078	2362	79.7
2026-05-02	886	1035	1921	6	1927	2040	113	151	1162	1078	2391	80.1
2026-05-03	934	1065	1999	6	2005	2306	301	152	1159	1078	2389	80.2
2026-05-04	899	1061	1960	9	1969	2254	285	151	1167	1079	2397	79.9
2026-05-05	855	1017	1872	10	1882	2210	328	149	1184	1078	2411	80.3
2026-05-06	1152	1061	2213	11	2224	2387	163	148	1185	1079	2412	80.1
2026-05-07	1301	1059	2360	8	2368	2619	251	146	1176	1078	2400	80.0
2026-05-08	932	1095	2027	11	2038	2444	406	144	1176	1078	2398	80.0
2026-05-09	921	1082	2003	7	2010	2178	168	142	1176	1079	2397	80.0
2026-05-10	959	1107	2066	9	2074	2299	225	140	1187	1065	2392	80.1
2026-05-11	918	1079	1997	8	2005	2238	233	139	1201	1057	2397	80.7
2026-05-12	898	1090	1988	10	1998	2363	365	138	1202	1056	2396	80.6
2026-05-13	950	1083	2033	7	2040	2302	262	136	1203	1058	2397	80.6
2026-05-14	917	1091	2008	7	2015	2258	243	133	1210	1057	2400	80.7
2026-05-15	916	1063	1979	7	1986	2149	163	132	1225	1057	2414	80.6
2026-05-16	857	1055	1912	8	1920	2286	366	131	1228	1057	2416	80.6
2026-05-17	847	1042	1889	7	1896	2058	162	127	1229	1057	2413	80.9
2026-05-18	920	1042	1962	9	1971	2374	403	127	1229	1057	2413	81.2
2026-05-19	915	1062	1977	8	1985	2104	119	62	1228	1057	2347	81.4
2026-05-20	876	1042	1918	10	1928	2231	303	39	1246	1057	2342	81.4
2026-05-21	920	1110	2030	11	2041	2290	249	40	1253	1057	2350	81.5
2026-05-22	943	1119	2062	10	2072	2309	237	57	1250	1057	2364	81.8
2026-05-23	962	1154	2116	12	2128	2445	317	54	1245	1057	2356	81.2
2026-05-24	1014	1146	2160	12	2172	2318	146	55	1245	1057	2357	81.5
2026-05-25	975	1167	2142	14	2156	2396	240	100	1245	1057	2402	81.6
2026-05-26	956	1132	2088	17	2105	2433	328	135	1244	1056	2435	81.7
2026-05-27	983	1118	2101	13	2114	2274	160	135	1245	1041	2421	81.6
2026-05-28	995	1166	2161	16	2177	2592	415	138	1264	1036	2438	81.5
2026-05-29	959	1145	2104	11	2115	2233	118	150	1314	938	2402	81.7
2026-05-30	907	1083	1990	11	2001	2315	314	182	1353	0	1535	81.5
2026-05-31	897	1058	1955	8	1963	2193	230	186	1399	0	1585	80.8
Min	847	1017	1872	6.13	1882	2040	113	39	1159	0	1535	79.7
Avg	944	1086	2030	9.67	2040	2292	252	124	1226	990	2340	80.8
Max	1301	1167	2360	16.82	2368	2619	415	186	1399	1079	2438	81.8
Total m3	29256	33671	62927	299.91	63227	71050	7823	3837	37996	30696	72529	

↑
Cells will highlight red if volume is more than 3000 m3 per day for DV.

11.01%
Loss

Full Level
End of Month
Average Month Volume

186,403
150,614
150,656

100.00%
80.8%