Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8, 4/7 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2026-08-01	1155	1298	2453	38	2491	2942	451	418	1012	1293	2723	95.9
2026-08-02	1146	1291	2437	31	2468	2649	181	416	1011	1293	2720	95.8
2026-08-03	1123	1295	2418	16	2434	2699	265	416	1012	1292	2720	95.7
2026-08-04	1090	1263	2353	28	2381	2575	194	414	1013	1292	2719	95.6
2026-08-05	1152	1257	2409	22	2431	2542	111	414	1011	1332	2757	95.4
2026-08-06	1093	1218	2311	22	2333	2656	323	415	1012	1378	2805	95.5
2026-08-07	1060	1148	2208	30	2238	2328	90	405	1012	1378	2795	95.7
2026-08-08	1099	1185	2284	31	2315	2674	359	412	1012	1378	2802	95.9
2026-08-09	1111	1213	2324	26	2350	2620	270	412	1012	1378	2802	95.9
2026-08-10	1082	1151	2233	16	2249	2421	172	414	1003	1379	2796	96.1
2026-08-11	970	1049	2019	13	2032	2268	236	412	986	1378	2776	96.2
2026-08-12	999	956	1954	6	1961	2071	111	358	986	1378	2722	97.2
2026-08-13	983	959	1942	8	1950	2156	207	308	987	1334	2629	97.8
2026-08-14	960	927	1887	9	1896	2155	260	312	987	716	2015	99.2
2026-08-15	921	923	1843	7	1851	2017	167	314	986	489	1789	98.5
2026-08-16	970	933	1903	8	1911	2217	306	314	986	1217	2517	98.6
2026-08-17	979	944	1923	17	1940	2220	280	356	685	1224	2265	98.9
2026-08-18	1005	947	1952	21	1973	2220	247	287	681	1224	2192	98.9
2026-08-19	1040	962	2001	15	2017	2153	137	268	771	1227	2266	98.9
2026-08-20	1015	968	1983	17	2000	2217	218	267	772	1228	2267	98.8
2026-08-21	995	946	1941	15	1956	2251	295	267	772	1227	2266	99.0
2026-08-22	966	966	1931	16	1948	2092	145	287	663	1227	2177	99.0
2026-08-23	1024	936	1960	16	1976	2138	163	275	600	1226	2101	98.9
2026-08-24	1022	976	1998	18	2016	2243	227	269	608	1226	2103	98.9
2026-08-25	1018	965	1982	16	1999	2416	418	281	634	1225	2140	98.6
2026-08-26	1065	1003	2068	18	2086	2221	135	276	601	1225	2102	98.2
2026-08-27	1077	1046	2123	20	2143	2465	322	271	608	1224	2103	98.0
2026-08-28	1065	989	2054	17	2071	2240	169	280	642	1224	2146	97.6
2026-08-29	1035	998	2033	14	2047	2275	228	276	623	1224	2123	97.4
2026-08-30	1051	948	1999	13	2012	2174	162	270	635	1224	2129	97.3
2026-08-31	1074	953	2027	11	2038	2190	153	280	659	1237	2176	97.4
Min	921	923	1843	6.39	1851	2017	90	267	600	489	1789	95.4
Avg	1043	1052	2095	18.01	2113	2339	226	334	838	1235	2408	97.4
Max	1155	1298	2453	37.81	2491	2942	451	418	1013	1379	2805	99.2
Total m3	**32342**	**32608**	**64950**	**558.38**	**65508**	**72505**	6997	**10364**	**25982**	**38297**	**74643**	

↑

Cells will highlight red if volume is more than 3000 m3 per day for DV.

9.65% Loss

Full Level	**186,403**	100.00%
End of Month	**181,557**	97.4%
Average Month Volume	**181,641**	