Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8, 4/7 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2026-07-01	922	1021	1943	7	1950	2295	345	622	1524	1207	3353	85.0
2026-07-02	1018	1063	2081	12	2093	2362	269	620	1546	1209	3375	85.7
2026-07-03	964	1132	2096	15	2111	2252	141	608	1601	1208	3417	86.1
2026-07-04	959	1091	2050	10	2060	2272	212	599	1552	333	2484	86.8
2026-07-05	967	1069	2036	7	2043	2256	213	570	1576	0	2146	86.4
2026-07-06	968	1040	2008	12	2020	2162	142	494	1544	0	2038	86.1
2026-07-07	972	1055	2027	12	2039	2456	417	627	1509	223	2359	86.1
2026-07-08	1079	1092	2171	24	2195	2406	211	634	1477	675	2786	86.1
2026-07-09	1078	1141	2219	18	2237	2501	264	641	1411	864	2916	86.8
2026-07-10	1052	1131	2183	18	2201	2396	195	645	1365	864	2874	87.0
2026-07-11	1093	1184	2277	20	2297	2412	115	643	1330	928	2901	87.3
2026-07-12	1116	1206	2322	23	2345	2456	111	642	1322	949	2913	87.8
2026-07-13	1098	1197	2295	30	2325	2776	451	645	1274	950	2869	88.2
2026-07-14	1024	1155	2179	14	2193	2408	215	644	1235	1199	3078	87.9
2026-07-15	1083	1187	2270	15	2285	2492	207	642	1216	1380	3238	88.5
2026-07-16	1148	1215	2363	22	2385	2529	144	646	1185	1416	3247	89.2
2026-07-17	1067	1170	2237	26	2263	2540	277	640	1155	1563	3358	89.8
2026-07-18	1083	1214	2297	30	2327	2507	180	640	1154	1639	3433	90.5
2026-07-19	1166	1238	2404	27	2431	2678	247	638	1137	1639	3414	91.1
2026-07-20	1031	1133	2164	14	2178	2543	365	636	1123	1639	3398	91.6
2026-07-21	980	1073	2053	22	2075	2292	217	635	1114	1639	3388	92.3
2026-07-22	1087	1163	2250	26	2276	2372	96	634	1093	1639	3366	92.9
2026-07-23	1099	1226	2325	26	2351	2613	262	636	1074	1639	3349	93.8
2026-07-24	1063	1180	2243	24	2267	2458	191	636	1057	1639	3332	94.5
2026-07-25	1104	1251	2355	24	2379	2623	244	634	1029	1638	3301	95.0
2026-07-26	1092	1241	2333	32	2365	2630	265	633	1028	1640	3301	95.3
2026-07-27	1225	1256	2481	26	2507	2744	237	551	1014	1639	3204	95.8
2026-07-28	1188	1230	2418	28	2446	2782	336	421	1012	1639	3072	95.9
2026-07-29	1164	1253	2417	24	2441	2564	123	422	1013	1422	2857	96.2
2026-07-30	1186	1239	2425	23	2448	2629	181	421	1012	1293	2726	95.8
2026-07-31	1157	1231	2388	26	2414	2481	67	417	1012	1293	2722	95.9
Min	922	1021	1943	6.54	1950	2162		417	1012	0	2038	85.0
Avg	1072	1164	2236	20.45	2256	2480	224	597	1248	1194	3039	90.2
Max	1225	1256	2481	32.36	2507	2782		646	1601	1640	3433	96.2
Total m3	**33236**	**36077**	**69313**	**633.95**	**69947**	**76887**	6940	**18516**	**38694**	**37005**	**94215**	

↑

Cells will highlight red if volume is more than 3000 m3 per day for DV.

9.03% Loss

Full Level	**186,403**	100.00%
End of Month	**178,760**	95.9%
Average Month Volume	**168,208**	