Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8, TW7 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2026-06-01	868	1035	1903	10	1913	2189	276	191	1486	0	1677	81.5
2026-06-02	852	1025	1877	9	1886	2168	282	229	1541	0	1770	81.2
2026-06-03	875	1042	1917	8	1925	2150	225	229	1621	0	1850	81.5
2026-06-04	889	1076	1965	8	1973	2170	197	228	1633	0	1861	81.7
2026-06-05	917	1091	2008	11	2019	2230	211	224	1633	0	1857	81.3
2026-06-06	918	1063	1981	15	1996	2312	316	218	1632	0	1850	80.8
2026-06-07	968	1071	2039	18	2057	2446	389	213	1632	0	1845	80.3
2026-06-08	1013	1104	2117	11	2128	2335	207	205	1633	0	1838	79.8
2026-06-09	918	1086	2004	12	2016	2319	303	371	1630	0	2001	79.7
2026-06-10	939	1046	1985	11	1996	2109	113	431	1610	0	2041	79.2
2026-06-11	960	1044	2004	10	2014	2315	301	421	1612	0	2033	79.2
2026-06-12	911	993	1904	9	1913	2074	162	419	1578	0	1997	79.1
2026-06-13	900	1003	1903	9	1912	2107	195	420	1546	0	1966	79.1
2026-06-14	1005	1099	2104	10	2114	2268	154	423	1508	0	1931	79.0
2026-06-15	968	1121	2089	13	2102	2598	496	329	1477	0	1806	78.8
2026-06-16	960	1074	2034	15	2049	2344	295	400	1469	0	1869	78.3
2026-06-17	957	1034	1991	8	1999	2104	105	601	1461	0	2062	78.8
2026-06-18	1014	1051	2065	11	2076	2356	280	598	1461	0	2059	77.9
2026-06-19	964	1049	2013	20	2033	2165	132	605	1392	0	1997	77.7
2026-06-20	928	1069	1997	8	2005	2289	284	599	1374	198	2171	77.6
2026-06-21	946	1078	2024	8	2032	2141	109	595	1376	611	2582	77.7
2026-06-22	969	1061	2030	10	2040	2457	417	599	1350	720	2669	77.9
2026-06-23	995	1061	2056	10	2066	2382	316	598	1309	891	2798	78.1
2026-06-24	1043	1093	2136	9	2145	2455	310	597	1284	956	2837	79.0
2026-06-25	1095	1132	2227	10	2237	2350	113	596	1271	972	2839	79.3
2026-06-26	994	1110	2104	9	2113	2357	244	590	1266	971	2827	79.4
2026-06-27	931	1067	1998	7	2005	2152	147	601	1249	971	2821	79.4
2026-06-28	925	1046	1971	7	1978	2240	262	604	1246	1110	2960	80.4
2026-06-29	934	1008	1942	7	1949	2265	316	619	1411	1209	3239	82.2
2026-06-30	876	1018	1894	7	1901	2151	250	641	1502	1207	3350	83.5
Min	852	993	1877	6.75	1886	2074		191	1246	0	1677	77.6
Avg	948	1062	2009	10.39	2020	2267	247	446	1473	327	2247	79.6
Max	1095	1132	2227	19.89	2237	2598		641	1633	1209	3350	83.5
Total m3	**28430**	**31850**	**60280**	**311.63**	**60592**	**67998**	7407	**13394**	**44193**	**9815**	**67402**	

↑

Cells will highlight red if volume is more than 3000 m3 per day for DV.

10.89% Loss

Full Level	**186,403**	100.00%
End of Month	**155,647**	83.5%
Average Month Volume	**148,464**	